

This inspection is for gas safety purposes only in accordance with the Gas Safety (I & U) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the Flue integrity, construction and lining has not been carried out.

Appliance details					Inspection details									
	Location	Type	Make	Model	Flue type	Operating value (see key below)	Safety device correct operation	Ventilation satisfactory	Flue performance		Visual condition of flue and termination satisfactory	Appliance safe*	Requested to test**	Indicate YES if unable to test**
									Flue flow test	Spillage test				
1	LOUNGE COMP	CHB	Potterton Myson	SUPRIMA 30	Room Sealed	9.3m	Yes	Yes	N/A	N/A	Yes	Yes	Yes	---
2	KITCHEN	HOB	Default	COOKERS - NO	Flueless	7.6k	Yes	Yes	N/A	N/A	Yes	Yes	Yes	---
3														
4														
5														

Details of any defects we found		What we've done	Labelled and warning notice given	Gas installation tightness test and visual inspection of pipework Next safety inspection due on 10th June 2027
1	Gas meter in another apartment.	Not Applicable	Not Applicable	
2				
3				
4				
5				
P				

This safety record has our engineer's electronic signature: Shane Merrigan 959451

Date: 11th June 2026

Job Number: 1708095486

Number of appliances tested: 2

It is a legal requirement that this record is kept for at least two years

Key for Operating Value

m = Operating Pressure in Millibars (mbars)
k = Gas Rates in kilowatts (kW)
c = Combustion Ratio CO/CO 2 ('c' will only be displayed where neither 'm' nor 'k' could be recorded i.e. an unmetred gas supply).

*If N/A is selected, it means we've done a visual check that showed no obvious defects. We recommend all gas appliances are serviced once a year to make sure they're safe. Please ask your engineer about this or book an appointment at britishgas.co.uk
**If Requested to test is NO or Unable to test is YES, please take a look at the back of this certificate

Contractor's Registration Number: _____

