

Energy performance certificate (EPC)

34B CASTLE STREET
SHREWSBURY
SY1 2BQ

Energy rating

D

Valid until 15 October 2030

Certificate number

9031-2254-0000-2490-6191

Property type

Mid-floor flat

Total floor area

34 square metres

Rules on letting this property


Properties can be rented if they have an energy rating from A to E.

The property is rated F or G, it cannot be let, unless an exemption has been registered. You can read [guidance for landlords on regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](#).

Energy efficiency rating for this property

The property's current energy rating is D. It has the potential to be C.

[See how to improve this property's energy performance.](#)



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Attribute	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Poor
Wall	Solid brick, as built, partial insulation (assumed)	Average
Window	Full secondary glazing	Good
Room heating	Room heaters, electric	Very poor
Room heating control	Programmer and appliance thermostats	Good
Point water	Electric instantaneous at point of use	Very poor
Lighting	Low energy lighting in all fixed outlets	Very good
Up of	(another dwelling above)	N/A
Down	(another dwelling below)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 337 kilowatt hours per square metre (kWh/m²).

What is primary energy use?

Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO₂). The energy used for heating, lighting and power in homes produces over a quarter of the UK's CO₂ emissions.

In average household produces 6 tonnes of CO₂

This property produces 1.9 tonnes of CO₂

This property's potential reduction 1.3 tonnes of CO₂

making the [recommended changes](#), you could reduce this property's CO₂ emissions by 0.6 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

How to improve this property's energy performance

aking any of the recommended changes will improve this property's energy efficiency.

ou make all of the recommended changes, this will improve the property's energy rating and move from D (62) to C (80).

What is an energy rating?

Recommendation 1: Internal or external wall insulation

Internal or external wall insulation

Typical installation cost £4,000 - £14,000

Typical yearly saving £239

Potential rating after carrying out recommendation 1

75 | C

Recommendation 2: High heat retention storage heaters

High heat retention storage heaters

Typical installation cost £400 - £600

Typical yearly saving £97

Potential rating after carrying out recommendations 1 and 2

80 | C

Paying for energy improvements

Find energy grants and ways to save energy in your home. (<https://www.gov.uk/improve-energy-efficiency>)

Estimated energy use and potential savings

Estimated yearly energy cost for this property	£703
Potential saving	£338

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](#).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Space heating	2684 kWh per year
Water heating	903 kWh per year

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
Solid wall insulation	1280 kWh per year

You might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](#). This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	Thomas Thorne
-----------------	---------------

Telephone

01743276666

mailtom.thorne@cgpooks.co.uk

Accreditation scheme contact details

Accreditation scheme

Stroma Certification Ltd

Assessor ID

STRO032613

Telephone

0330 124 9660

mailcertification@stroma.com

Assessment details

Assessor's declaration

Employed by the professional dealing with the property transaction

Date of assessment

14 October 2020

Date of certificate

16 October 2020

Type of assessment► [RdSAP](#)

Other certificates for this property

You are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digitalservices@communities.gov.uk, or call our helpdesk on 020 3829 0748.

Certificate number[9255-2833-6706-0728-4325 \(energy-certificate/9255-2833-6706-0728-4325\)](#)

Valid until

2 November 2018 (Expired)

