

Gas Safety Record

Gas Safe Register is a registered trademark of the HSE and is used under licence



Serial No: 000136 Number of appliances: 2 This Gas Safety Record was completed on 29 Jan 2026 by Shakil Ahmed, 916549.

Your next Gas Safety Check can be completed from 29 Nov 2026 and is due by 29 Jan 2027

Registered Business Turbo Gas and Heating Address: 35 Thornton Road Postcode: SM5 1NL	Gas Safe No: 916549 Phone: 07828632707	Job Address Name: Mr Shakeel Ahmad Address: 87 Morden Road Mitcham Postcode: CR44DF	Client Details Client Name: Address: Postcode: Phone:
--	---	--	---

Location	Appliance type	Make	Model	Landlord's appliance	Appliance inspected	Appliance serviced	Appliance safe to use
1 Other	Boiler	Vaillant	Ecofit pure 835	Yes	Yes	Yes	Yes
2 Kitchen	Hob	Indesit	—	Yes	Yes	No	Yes
3							
4							
5							

Operating pressure (Mbar)	Heat input (kW/h or btu/h)	Initial combustion analyser reading	Final combustion analyser reading	Safety device correct operation	Ventilation provision satisfactory	Visual condition of chimney/termination satisfactory	Flue type	Spillage test	Smoke pellet flue flow test	Flue visual condition	Flue performance checks	Approved CO alarm fitted	Is CO alarm in date	Testing of CO alarm satisfactory
1 20 Mbar	28.9	0.0005	0.0007	Yes	Yes	n/a	RS	n/a	n/a	Pass	Pass	Yes	Yes	Yes
2 20 Mbar	8.2	—	—	Yes	Yes	n/a	FL	n/a	n/a	n/a	n/a	Yes	Yes	Yes
3														
4														
5														

Defects	Actions taken	Warning Notice
1 —	—	—
2 —	—	—
3		
4		
5		

Gas Installation	Issued by 22	Received by
Gas Installation pipework visual inspection satisfactory	Yes	Sh
Emergency control valve (ecv) accessible	Yes	Sehar Noor
Satisfactory gas tightness test	Yes	Sehar Noor
Protective equipotential bonding satisfactory	Yes	Sehar Noor
Gas Installation Notes: —		
Gas Installation Warning Notice Completed	N/A	Sehar Noor
Electrical Cross Bonding Notice Completed	N/A	Sehar Noor

This record allows results of the required checks defined by the Gas Safety (Installation and Use) Regulations to be recorded. The information recorded does not confirm that the installation was installed by a Registered Installer or that the Installation complies with any relevant Building Regulations. Chimney Systems were inspected visually and checked for satisfactory evacuation products of combustion, please note a detailed internal inspection of the chimney system has not been carried out. WARNING : Please read and act upon the Warning Notice and/or Electrical Cross Bonding Record if applicable