

This inspection is for gas safety purposes only to comply with Gas Safety (Installation and Use) Regulations. Flues have been inspected and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.


Company details	Job address	Landlord/Agent	Certificate information
Shropshire Gas Ltd Bridge Road, Wellington, Telford TF1 1EA 01952 259019 Gas safe id: 10866	11 Conway Drive Telford Estate Sy2 5UA	Tom Ridler / Marshall & Marshall## Marshall and Marshall 9 College Hill Shrewsbury Shropshire, SY1 1LZ	Date: 6/01/2026 Certificate number: CP12-9868 Certificate is valid until: 06/01/2027

No	Location	Appliance type	Make/model	Flue type	Landlords appliance	Appliance inspected?	Combustion analyser reading	Operating pressure (mbar)	heat input (kW)	Safety device(s) correct and operational
1	Airing Cupboard	Boiler	Worcester Greenstar 24i JR	RS	Yes	Yes	0008	18.5		Yes
2										
3										
4										

No	Ventilation provision satisfactory	Visual condition of flue & termination satisfactory	Flue performance checks	Appliance serviced?	Appliance safe to use?	Approved Co alarm fitted?	Is Co alarm in date?	Testing of Co alarm satisfactory?
1	Yes	Yes	Pass	Yes	Yes	Yes	N/A	Yes
2								
3								
4								

No	Defect(s) identified	Remedial action taken	Warning notice issued?
1			
2			
3			
4			

Number of appliances tested?	1
Gas installation pipework (visual inspection) satisfactory?	Yes
Gas tightness test satisfactory?	Yes
Emergency control valve accessible?	Yes
Protective equipotential bonding satisfactory?	No

Engineer information	Received by information	Comments
Engineer name: Chris Edwards Gas safe licence number: 10866 	Position: Customer Received by: Ash 	

No	Working pressure at meter (mbar)	Working appliance pressure/burner pressure (mbar)	Co parts per million	Co2%	o2%	Co/co2 ratio	Gross flue temperature (°c)	Gas rate (kW)
1		18.5	76	9.75	3.8	0008		
2								
3								
4								