



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. No detailed internal inspection of flues (Integrity, Constructions and Lining) has been carried out.

Certificate Reference

Foots Cray Stables

Certificate No: 100013

Engineers Details		Installation Details		Client Details	
Trading Title	Chislehurst Plumbing & Heating Ltd	Installation Address	Foots Cray Stables Rectory Lane Sidcup Post Code: DA14 5BP	Client Address	Clyde Richardson Foots Cray Stables Rectory Lane Sidcup Post Code: DA14 5BP
Address	Castries Palace Road Westerham Post Code: TN16 2EH				
Gas Safe No:	538893	Telephone No:	02031724397	Telephone No:	

Appliance Details				Inspection Details													
Location	Appliance Type	Make	Model	CO2 Reading	CO Reading	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(KW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)	
Garage	Central heating boiler	Worcester	Greenstar 35cdi Sy	9.3	46	RS	YES	0.0005	YES	19 mbar	YES	YES	YES	PASS	NO	YES	

Faults/Notes	Remedial Work Taken	Warning Notice Fixed
1		
2		
3		
4		
5		

Emergency Control Valve accessible:	<input type="checkbox"/> YES	Gas Tightness Satisfactory:	<input type="checkbox"/> YES	Signatures		Gas ID Number:	4457268
Gas Installation Pipework Visual Inspection Satisfactory:	<input type="checkbox"/> YES	Report Issued By:	Name: Oliver Routledge	Signed:	Date:	Thu-27-02-2020	
Number Of Appliances Tested:	1	Report Received By:	Name: Clyde Richardson	Signed:	Date:	Thu-27-02-2020	
NEXT INSPECTION DUE ON OR BEFORE:	Fri-26-02-2021	Installation Pass:	<input type="checkbox"/> Yes				