

This inspection is for gas safety purposes only to comply with Gas Safety (Installation and Use) Regulations. Flues have been inspected and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

Company details	Job address	Landlord/Agent	Certificate information
Shropshire Gas Ltd Bridge Road, Wellington, Telford TF1 1EA 01952 259019 Gas safe id: 10866	Flat 4 ,61 Abbey Foregate, Shrewsbury SY2 6BQ, UK	Tom Ridler / Marshall & Marshall## Marshall and Marshall 9 College Hill Shrewsbury Shropshire, SY1 1LZ	Date: 4/02/2026 Certificate number: CP12-10007 Certificate is valid until: 20/01/2027

No	Location	Appliance type	Make/model	Flue type	Landlords appliance	Appliance inspected?	Combustion analyser reading	Operating pressure (mbar)	heat input (kW)	Safety device(s) correct and operational
1	Kitchen	Boiler	Worcester Greenstar 24i JR	RS	Yes	Yes	0011		24.22	Yes
2	Kitchen	Cooker	Lamona N/A	FL	Yes	Yes				Yes
3										
4										

No	Ventilation provision satisfactory	Visual condition of flue & termination satisfactory	Flue performance checks	Appliance serviced?	Appliance safe to use?	Approved Co alarm fitted?	Is Co alarm in date?	Testing of Co alarm satisfactory?
1	Yes	Yes	Pass	Yes	Yes	Yes	Yes	Yes
2	Yes	N/A	N/A	No	Yes	Yes	Yes	Yes
3								
4								

No	Defect(s) identified	Remedial action taken	Warning notice issued?	Number of appliances tested?	
1				2	
2				Gas installation pipework (visual inspection) satisfactory?	Yes
3				Gas tightness test satisfactory?	Yes
4				Emergency control valve accessible?	Yes
				Protective equipotential bonding satisfactory?	Yes

Engineer information	Received by information	Comments
Engineer name: Chris Edwards Gas safe licence number: 10866 	Position: No person present Received by: N/A	

No	Working pressure at meter (mbar)	Working appliance pressure/burner pressure (mbar)	Co parts per million	Co2%	o2%	Co/co2 ratio	Gross flue temperature (°c)	Gas rate (kW)
1			111	10.11	3.2	0011		24.22
2								
3								
4								