

# Energy performance certificate (EPC)

21 Swiss Avenue  
WATFORD  
WD18 7LL

Energy rating

C

Valid until:

26 May 2032

Certificate number:

1900-7536-8022-5021-1523

Property type

Semi-detached house

Total floor area

137 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy rating and score

This property's energy rating is C. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

| Score | Energy rating | Current | Potential |
|-------|---------------|---------|-----------|
| 92+   | A             |         |           |
| 81-91 | B             |         | 81 B      |
| 69-80 | C             | 70 C    |           |
| 55-68 | D             |         |           |
| 39-54 | E             |         |           |
| 21-38 | F             |         |           |
| 1-20  | G             |         |           |

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                    | Rating    |
|----------------------|------------------------------------------------|-----------|
| Wall                 | Solid brick, as built, no insulation (assumed) | Very poor |
| Wall                 | Cavity wall, as built, insulated (assumed)     | Good      |
| Roof                 | Pitched, no insulation (assumed)               | Very poor |
| Roof                 | Flat, insulated (assumed)                      | Good      |
| Window               | Fully double glazed                            | Good      |
| Main heating         | Boiler and radiators, mains gas                | Good      |
| Main heating         | Boiler and underfloor heating, mains gas       | Very good |
| Main heating control | Programmer, room thermostat and TRVs           | Good      |
| Main heating control | Time and temperature zone control              | Very good |
| Hot water            | From main system                               | Good      |
| Lighting             | Low energy lighting in 91% of fixed outlets    | Very good |
| Floor                | Suspended, no insulation (assumed)             | N/A       |
| Floor                | Solid, insulated (assumed)                     | N/A       |
| Secondary heating    | None                                           | N/A       |

### Primary energy use

The primary energy use for this property per year is 186 kilowatt hours per square metre (kWh/m<sup>2</sup>).

---

## How this affects your energy bills

An average household would need to spend **£933 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £129 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2022** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

## Heating this property

Estimated energy needed in this property is:

- 14,232 kWh per year for heating
  - 2,968 kWh per year for hot water
-

## Impact on the environment

This property's environmental impact rating is D. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year.

### Carbon emissions

An average household produces 6 tonnes of CO<sub>2</sub>

---

This property produces 4.5 tonnes of CO<sub>2</sub>

This property's potential production 2.7 tonnes of CO<sub>2</sub>

---

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

---

## Steps you could take to save energy

| Step                         | Typical installation cost | Typical yearly saving |
|------------------------------|---------------------------|-----------------------|
| 1. Internal wall insulation  | £4,000 - £14,000          | £85                   |
| 2. Solar water heating       | £4,000 - £6,000           | £44                   |
| 3. Solar photovoltaic panels | £3,500 - £5,500           | £355                  |

## Advice on making energy saving improvements

[Get detailed recommendations and cost estimates \(www.gov.uk/improve-energy-efficiency\)](http://www.gov.uk/improve-energy-efficiency)

## Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Heat pumps and biomass boilers: [Boiler Upgrade Scheme \(www.gov.uk/apply-boiler-upgrade-scheme\)](http://www.gov.uk/apply-boiler-upgrade-scheme)
-

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                 |                                                                                        |
|-----------------|----------------------------------------------------------------------------------------|
| Assessor's name | Sophie Nugent                                                                          |
| Telephone       | 02039056099                                                                            |
| Email           | <a href="mailto:sophienugent@fourwalls-group.com">sophienugent@fourwalls-group.com</a> |

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                      |                                                                        |
|----------------------|------------------------------------------------------------------------|
| Accreditation scheme | Stroma Certification Ltd                                               |
| Assessor's ID        | STRO036803                                                             |
| Telephone            | 0330 124 9660                                                          |
| Email                | <a href="mailto:certification@stroma.com">certification@stroma.com</a> |

### About this assessment

|                        |                       |
|------------------------|-----------------------|
| Assessor's declaration | No related party      |
| Date of assessment     | 27 May 2022           |
| Date of certificate    | 27 May 2022           |
| Type of assessment     | <a href="#">RdSAP</a> |

---